




P.O. Box 1026
Crossville, TN 38557
Ph. 931-484-7541
www.uplanddesigngroup.com

Addendum No. 2, May 2, 2025

Re: Teaching Headhouse Renovation
Tennessee Technological University
SBC# 364/021-01-2024
Cookeville, TN

From: Upland Design Group, Inc.
P.O. Box 1026 (38557)
362 Industrial Blvd.
Crossville, TN 38555
Telephone (931) 484 7541
Fax (931) 484 2351



To: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 8-27-24 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of one (1) page and no attachments.

Clarifications:

- 1) Exterior metal studs shall be 20 ga.
- 2) There are no Alternates on the Project.
- 3) A Roof Bond is not required. Existing roof to remain.
- 4) The Project requires Davis Bacon Wage Rates with certified payroll.

Approved Substitutions:

- 5) Refer to Section 01 23 00 Omit this Section. There are no Alternates.
- 6) Specification Section 10 21 00 Compartments and Cubicles – Hiny Hiders Solid Plastic – by Scranton Products is approved.

END OF ADDENDUM