



**Maffett Loftis Engineering, LLC**

1 South Jefferson Avenue, Suite 101

Cookeville, TN 38501

Tel: (931) 526-5143

[www.maffett-loftis.com](http://www.maffett-loftis.com)

---

**Addendum No. 3 January 13, 2025  
Multi-Building Elevator Upgrades  
Tennessee Technological University  
Cookeville, Tennessee  
SBC 364-011-02-2023**

This addendum is to provide the contractors with the answers to submitted questions, clarifications to the plans, and revisions to the plans.

The following items take precedence over that previously specified for the referenced project:

1. Existing light fixtures shall be demolished.
2. A new wet listed 4' strip light shall be installed in the pit on the lower-level door side of each elevator.
3. Relocate the pit maintenance receptacles above the lower floor level.
4. RUC Elev 3 (i.e., kitchen service elevator):
  - a. Clarification: the existing traction controller shall remain.

End of Addendum

Addendum issued by:

Gary D Loftis, PE  
Maffett Loftis Engineering, LLC

Attachments:  
None